

Supplement Analysis
for the
Transmission System Vegetation Management Program EIS
(DOE/EA/EIS-0285/SA-859)

Pollution Prevention and Abatement Project Number 4917
Natural Resource Specialist/Project Manager: Jacob Marti

Bonneville Power Administration
Department of Energy



Proposed Activities

Bonneville Power Administration (BPA) proposes to clear unwanted vegetation in and adjacent to the transmission line corridors and access roads in the BPA Redmond district. Vegetation management needs were assessed and Vegetation Control Cut Sheets were created and compiled for the following corridors:

- 500-kilovolt (kV) Ashe-Marion No. 2 corridor from structure 150/2 to 174/3. This corridor includes the 500-kV John Day-Marion No. 1 transmission line from structure 57/5 to structure 58/2.
- 500-kV Captain Jack-Malin No. 1 corridor, from Captain Jack Substation to Malin Substation. This corridor includes the 500-kV Captain Jack-Olinda No. 1 transmission line from Captain Jack Substation to structure 7/3.

The right-of-way (ROW) corridor in the proposed project area measures from 150 to 300 feet in width and crosses approximately 35 miles of terrain through rural residential, private forest, agricultural, and lands managed by Oregon state, United States Bureau of Land Management-Lakeview District, United States Forest Service – Mount Hood National Forest, and Confederated Tribes of the Warm Springs in Wasco, Clackamas, and Klamath counties, Oregon.

Coordination with public land managers has occurred. Additionally, letters, on-site meetings, emails, and phone calls would be used to notify landowners approximately three weeks prior to commencing vegetation management activities. Door hangers would also be used at properties where special treatments are anticipated. Any additional measures proposed by landowners or land managers through ongoing communication would be incorporated into the vegetation management plan during project implementation.

To comply with Western Electricity Coordinating Council standards, BPA proposes to manage vegetation with the goal of removing tall-growing vegetation that is currently or will soon become a hazard to the transmission line (a hazard is defined as one or more branches, tops, and/or whole trees that could fall or grow into the minimum safety zone of the transmission line(s) causing an electrical arc, relay, and/or outage). The overall goal of BPA is to establish low-growing plant communities along the right-of-way (ROW) to control the development of potentially threatening vegetation.

A combination of selective and nonselective vegetation control methods would be used to perform the work, and may include hand cutting, mowing, herbicidal treatment, or a combination of those methods. Herbicides would be selectively applied using spot treatment (stump or stubble treatment, basal treatment, and/or spot foliar) or localized treatments

(broadcast application and cut stubble treatments) with chemicals approved in BPA's Transmission System Vegetation Management Program Final Environmental Impact Statement (FEIS) (DOE/EIS-0285, May 2000), to ensure that the roots are killed - preventing new sprouts - and selectively eliminating vegetation that interferes with the operation and maintenance of transmission infrastructure.

Approximately 1,200 acres of ROW, and 10 miles of access road would be treated in 2023/2024. In addition, BPA proposes to remove approximately 65 trees in, or adjacent to, the ROW. Additional vegetation management may be necessary in subsequent years of the vegetation management cycle in discrete areas of noxious weeds, or where BPA personnel discover vegetation that poses a hazard to the transmission line. All debris would be disposed of onsite, along the ROW, using on-site chip, lop and scatter, or mulching techniques.

Analysis

Vegetation Control Cut Sheets were developed for these corridors that incorporated the requirements identified in BPA's Transmission System Vegetation Management Program FEIS and Record of Decision (August 23, 2000). The following summarizes natural resources occurring in the project area along with applicable mitigation measures outlined in the Vegetation Control Cut Sheets.

Water Resources

Water bodies (streams, rivers, lakes, wetlands) occurring in the project area are noted in the Vegetation Control Cut Sheets. As conservation and avoidance measures, only spot and localized treatment with Garlon 3A (Triclopyr TEA) would be used within a 100-foot buffer up to the water's edge of any stream containing threatened or endangered species. Trees in riparian zones would be selectively cut to include only those that would grow into the minimum approach distances of the conductor at maximum sag; other trees would be left in place or topped to preserved shade. Shrubs that are less than 10-feet-high would not be cut where ground to conductor clearance allows. No ground-disturbing vegetation management methods would be implemented, thus eliminating the risk for soil erosion and sedimentation near the streams. Where private water wells/springs or agricultural irrigation sources have been identified along the ROW and noted in the Vegetation Control Cut Sheets, no herbicide application would occur within a 50-foot radius of the wellhead, spring, or irrigation source (164 feet when using herbicides with ground/surface water advisory).

Endangered Species Act and Magnuson-Stevens Act

Pursuant to its obligations under the Endangered Species Act (ESA), BPA made a determination of whether its proposed project would have any effects on any listed species. A species list was obtained for federally-listed, proposed, and candidate species potentially occurring within the project boundaries from the United States Fish and Wildlife Service (USFWS). Based on the ESA review conducted, BPA made a determination that the project would have "No Effect" for all ESA-listed species and designated critical habitat under USFWS' jurisdiction.

BPA conducted a review of ESA-listed species and Essential Fish Habitat (as defined by the Magnuson-Stevens Act), under the jurisdiction of the National Oceanic and Atmospheric Administration, National Marine Fisheries Service (NMFS). The proposed vegetation management activities are within the scope of activities and action area evaluated in the Endangered Species Act Section 7 Programmatic Conference and Biological Opinion and Magnuson-Stevens Fishery Conservation and Management Act Essential Fish Habitat Consultation for Standard Local Operating Procedures for Endangered Species to Administer Maintenance or Rebuild Projects for Transmission Line and Road Access Actions Authorized or Carried Out by the Bonneville Power Administration in Oregon, Washington, and Idaho (SLOPES PBO) (WCR-2014-1600, September 22, 2016). Streams in the project area with documented presence of ESA-listed fish, designated as critical habitat for one or more species, and/or identified as Essential Fish Habitat (EFH) were noted in the vegetation control prescription. It was determined that, by complying

with the project design criteria listed within the SLOPES PBO, potential effects to ESA-listed anadromous salmonids and EFH would be consistent with those evaluated and addressed in the SLOPES PBO.

Cultural Resources

The proposed vegetation management actions do not result in ground disturbance to the physical environment, so the action is not one that typically has the potential to affect historic and/or cultural resources. If a site is discovered during the course of vegetation control, work would be stopped in the vicinity and the BPA Environmental Specialist and the BPA Archaeologist would be contacted.

Re-Vegetation

Existing naturalized grasses and woody shrubs are present on the entire ROW and are expected to naturally seed into the areas that would have lightly-disturbed soil predominantly located on the ROW roads.

Monitoring

The entire project would be inspected during the work period, winter 2023 through fall 2024. A follow-up treatment may occur after the initial treatment. Additional monitoring for follow-up treatment would be conducted as necessary. A vendor scorecard would be used to document formal inspections and would be filed with the contracting officer.

Findings

BPA finds that the types of actions and the potential impacts related to the proposed activities have been examined, reviewed, and consulted upon and are similar to those analyzed in the Transmission System Vegetation Management Program FEIS (DOE/EIS-0285) and ROD. There are no substantial changes in the EIS's Proposed Action and no significant new circumstances or information relevant to environmental concerns bearing on the EIS's Proposed Action or its impacts within the meaning of 10 CFR § 1021.314(c)(1) and 40 CFR § 1502.9(d). Therefore, no further NEPA analysis or documentation is required.

/s/ Steven D. Selser

Steven D. Selser
Biological Scientist (Environmental)

Concur:

/s/ Katey Grange

Katey Grange
NEPA Compliance Officer Date: November 1, 2023

References:

Vegetation Control Cut Sheets