

Supplement Analysis
for the
Transmission System Vegetation Management Program EIS
(DOE/EA/EIS-0285/SA-886)

Pollution Prevention and Abatement Project Number 5071
Natural Resource Specialist/Project Manager: Jennifer Austin – TFBV-CHEMAWA

Bonneville Power Administration
Department of Energy



Proposed Activities

BPA proposes to clear unwanted vegetation in and adjacent to transmission line corridors and access roads in the BPA Salem district in Benton, Clackamas, Linn, Marion, Polk, Washington, and Yamhill counties, Oregon specifically: Adair Tap to Salem – Albany No 2, Big Eddy-Chemawa No 1, Carlton – Sherwood No 1, Cascade Steel Tap to Carlton - Sherwood No 1, Chemawa – Salem No 1, Chemawa – Salem Alumina No 1, Filbert Tap to Forest Grove-McMinnville No 1, Forest Grove – McMinnville No 1, Keeler – Oregon City No 2, Marion – Alvey No 1, Marion – Santiam No 1, Oregon City – Canby PGE No 1, Oregon City – Chemawa No 2, Salem – Albany No 1, Salem – Albany No 2, Santiam – Alvey 1&2 No 2, Santiam – Chemawa No 1. Vegetation management needs were assessed, and Vegetation Control Cut Sheets were created for the right-of-way corridor and associated access roads along these transmission assets.

This SA does not assess vegetation management activities on the Marion-Alvey No 1 transmission line from structures 2/4 to 3/2 and 11/4 to 12/2. Also, activities on the Chemawa-Salem Alumina No 1 transmission line from structures 1/16 to 1/20 and from structures 2/2 to 2/6.

The corridors in the proposed project area measures approximately 40 to 500 feet wide and 225 miles long. The corridors run through primarily private lands, but some tracts are managed by the U.S. Fish and Wildlife Service – Ankeny National Wildlife Refuge, the Bureau of Land Management – Northwest Oregon District, and Oregon Department of State Lands. Land use is varied, with urban, suburban, agricultural, forestry, commercial, industrial, and park/recreational uses are present along the ROW corridors.

The State and Federal Land management agencies in the area have been notified of potential actions by the BPA Natural Resources Specialist and have not expressed any concerns. On-site meetings, emails, and phone calls would be used to notify other landowners approximately three weeks prior to commencing vegetation management activities. Door hangers would also be used at properties where special treatments are anticipated. Any additional measures proposed by landowners or land managers through ongoing communication would be incorporated into the vegetation management plan during project implementation.

To comply with Western Electricity Coordinating Council standards, BPA proposes to manage vegetation with the goal of removing tall-growing vegetation that is currently or will soon become a hazard to the transmission line (a hazard is defined as one or more branches, tops, and/or whole trees that could fall or grow into the minimum safety zone of the transmission line(s) causing an electrical arc, relay, and/or

outage). The overall goal of BPA is to establish low-growing plant communities along the right-of-way (ROW) to control the development of potentially threatening vegetation.

A combination of selective and nonselective vegetation control methods would be used to perform the work, and may include hand cutting, mowing, herbicidal treatment, or a combination of those methods. To ensure that the roots are killed, prevent re-sprouts, and selectively manage vegetation that interferes with the operation and maintenance of transmission infrastructure, herbicides would be selectively applied using spot treatment (stump treatment) or localized treatments (basal treatment and/or low-volume foliar treatment). For worker safety and fire prevention, broad-spectrum (non-selective) residual herbicide would be applied, and only applied immediately adjacent to switch platforms and selected transmission structures (primarily wood poles). All herbicides and adjuvants would be chosen from a list of approved chemicals in BPA's Transmission System Vegetation Management Program Final Environmental Impact Statement (FEIS) (DOE/EIS-0285, May 2000) and subsequent supplement analyses to the FEIS.

Approximately 1,900 acres of right-of-way, 5 miles of access roads, and 820 structure sites would be initially treated starting in winter 2024. In addition, BPA proposes to remove approximately 90 trees in, or adjacent to the right-of-way, and to remove limbs from approximately 415 trees in, or adjacent to the right-of-way. A follow-up treatment of re-sprouting target vegetation would be conducted by fall 2025. Additional vegetation management may be necessary in subsequent years of the vegetation management cycle in discrete areas of noxious weeds, or where BPA personnel discover vegetation that poses a hazard to the transmission line. All debris would be disposed of onsite, along the ROW, using on-site chipping/mulching, or cut, lop, and scatter techniques

Analysis

A Vegetation Control Cut Sheet was developed for this corridor that incorporated the requirements identified in BPA's Transmission System Vegetation Management Program FEIS and Record of Decision (August 23, 2000). The following summarizes natural resources occurring in the project area along with applicable mitigation measures outlined in the Vegetation Control Cut Sheets.

Water Resources

Water bodies (streams, rivers, lakes, wetlands) occurring in the project area are noted in the Vegetation Control Cut Sheets. As conservation and avoidance measures, only spot and localized treatment with Garlon 3A (Triclopyr TEA) would be used within a 100-foot buffer up to the water's edge of any stream containing threatened or endangered species. Trees in riparian zones would be selectively cut to include only those that would grow into the minimum approach distances of the conductor at maximum sag; other trees would be left in place or topped to preserved shade. Shrubs that are less than 10-feet-high would not be cut where ground to conductor clearance allows. No ground-disturbing vegetation management methods would be implemented, thus eliminating the risk for soil erosion and sedimentation near the streams. Where private water wells/springs or agricultural irrigation sources have been identified along the ROW and noted in the Vegetation Control Cut Sheets, no herbicide application would occur within a 50-foot radius of the wellhead, spring, or irrigation source (164 feet when using herbicides with ground/surface water advisory).

Endangered Species Act and Magnuson-Stevens Act

Pursuant to its obligations under the Endangered Species Act (ESA), BPA made a determination of whether its proposed project would have any effects on any listed species. A species list was obtained for federally-listed, proposed, and candidate species potentially occurring within the project boundaries from the United States Fish and Wildlife Service (USFWS). Based on the ESA review conducted, BPA made a determination that the project would have "No Effect" for all ESA-listed species and designated critical habitat under USFWS' jurisdiction.

BPA conducted a review of ESA-listed species and Essential Fish Habitat (EFH) (as defined by the Magnuson-Stevens Act), under the jurisdiction of the National Oceanic and Atmospheric Administration, National Marine Fisheries Service (NMFS). The proposed vegetation management activities are within the scope of activities and action area evaluated in the Endangered Species Act Section 7 Programmatic Conference and Biological Opinion and Magnuson-Stevens Fishery Conservation and Management Act Essential Fish Habitat Consultation for Standard Local Operating Procedures for Endangered Species to Administer Maintenance or Rebuild Projects for Transmission Line and Road Access Actions Authorized or Carried Out by the Bonneville Power Administration in Oregon, Washington, and Idaho (SLOPES PBO) (WCR-2014-1600, September 22, 2016). Streams in the project area with documented presence of ESA-listed fish, designated critical habitat for one or more species, and/or identified as EFH have been noted in the Vegetation Control Cut Sheets. It was determined that, by complying with the project design criteria listed within the SLOPES PBO, potential effects to ESA-listed anadromous salmonids and EFH would be consistent with those evaluated and addressed in the SLOPES PBO.

Cultural Resources

The proposed vegetation management actions do not result in ground disturbance to the physical environment, so the action is not one that typically has the potential to affect historic and/or cultural resources. If a site is discovered during the course of vegetation control, work would be stopped in the vicinity and the BPA Environmental Specialist and the BPA Archaeologist would be contacted.

Re-Vegetation

Existing naturalized grasses and woody shrubs are present on the entire ROW and are expected to naturally seed into the areas that would have lightly-disturbed soil predominantly located on the ROW roads.

Monitoring

The entire project would be inspected during the work period, winter 2024 through fall 2025. A follow-up treatment may occur after the initial treatment. Additional monitoring for follow-up treatment would be conducted as necessary. A vendor scorecard would be used to document formal inspections and would be filed with the contracting officer.

Findings

BPA finds that the types of actions and the potential impacts related to the proposed activities have been examined, reviewed, and consulted upon and are similar to those analyzed in the Transmission

System Vegetation Management Program FEIS (DOE/EIS-0285) and ROD. There are no substantial changes in the EIS's Proposed Action and no substantial new circumstances or information about the significance of the adverse effects that bear on the analysis in the EIS's Proposed Action or its impacts within the meaning of 10 CFR § 1021.314 and 40 CFR § 1502.9. Therefore, no further NEPA analysis or documentation is required.

/s/ Steven Selser

Steven Selser EPR – CHEMAWA
Physical Scientist (Environmental)

Concur:

/s/ Katey Grange

Katey Grange
NEPA Compliance Officer Date: October 9, 2024

References:

Vegetation Control Cut Sheets