

B O N N E V I L L E
P O W E R A D M I N I S T R A T I O N



**Transmission Reliability Margin
Implementation Document**

Version 910

(North American Energy Standards Board WEQ-023MOD-008-1)

**Bonneville Power Administration
Transmission Services**

Effective Date: ~~September 27, 2023~~ February 01, 2024

TABLE OF CONTENTS

I. Purpose	3
II. Definitions	3
III. Transmission Reliability Margin Calculation Methodology.....	3
IV. TRMID Requests.....	6
V. Version History	7
I. Purpose	3
II. Definitions	3
III. Transmission Reliability Margin Calculation Methodology.....	3
Components of Uncertainty	3
IV. TRMID Requests.....	5
V. Version History	6

I. Purpose

This Transmission Reliability Margin Implementation Document (TRMID) addresses the requirements of [North American Electric Reliability Corporation \(NERC\) reliability standard MOD-008-1 \(Transmission Reliability Margin Calculation Methodology\)](#) and North American Energy Standards Board (NAESB) Wholesale Electric Quadrant business practice standard WEQ-023. This TRMID applies to TRM calculations through month 13.

II. Definitions

All capitalized terms used in this TRMID are contained in NERC's Glossary of Terms ~~used in NERC Reliability Standards~~.

III. Transmission Reliability Margin Calculation Methodology

~~This section describes how BPA implements the requirements of MOD-008-1. BPA calculates and maintains a Transmission Reliability Margin (TRM) across its Northern Intertie N>S, Northern Intertie S>N and Satsop Injection ATC paths.~~

~~Components of Uncertainty~~

~~BPA uses the following components of uncertainty to establish TRM on its Northern Intertie N>S and S>N paths (MOD-008-1 R1.1):~~

~~○ Variations in generation dispatch (including, but not limited to, forced or unplanned outages, maintenance outages and location of future generation).~~

~~○ Inertial response and frequency bias.~~

~~BPA uses the following component of uncertainty to establish additional TRM on its Northern Intertie S>N path (MOD-008-1 R1.1):~~

~~○ Allowances for simultaneous path interactions.~~

~~BPA uses the following component of uncertainty to establish TRM on its Satsop Injection path (MOD-008-1 R1.1):~~

~~○ Forecast uncertainty in Transmission system topology (including, but not limited to, forced or unplanned outages and maintenance outages).~~

~~BPA does not maintain TRM on any other of its paths.~~

BPA does not maintain Capacity Benefit Margin (CBM) on any of its ATC paths, and therefore does not include any of the components of CBM in its TRM calculations. ~~(MOD-008-1 R2)~~

~~Allocating TRM values across the Northern Intertie path N>S and Northern Intertie S>N~~

31 BPA uses the following components of uncertainty to establish TRM on its Northern Intertie
32 N>S and S>N ATC paths (MOD-008-1 R1.1):

33 ○ Variations in generation dispatch (including, but not limited to, forced or unplanned
34 outages, maintenance outages and location of future generation).

35 ○ Inertial response and frequency bias.

36 BPA uses the following component of uncertainty to establish additional TRM on its Northern
37 Intertie S>N ATC path (MOD-008-1 R1.1):

38 ○ Allowances for simultaneous path interactions.

39

40 To calculate the TRM for the Northern Intertie path due to uncertainty arising from variations
41 in generation dispatch and inertial response and frequency bias, BPA's Transmission System
42 Operations organization

43 conducted a post event analysis in 2013. The results of this analysis are validated every 13
44 months based on operating experience and the capacity amount that has proven sufficient
45 and effective to mitigate such uncertainty in the past. (MOD-008-1 R1.2)

46 BPA's Transmission System Operations studies have shown that there is an interaction
47 between flows on the Northern Intertie S>N path and flows on the AC Intertie (NWACI) N>S
48 and North of Hanford N>S paths. In order to mitigate the uncertainty that results from this
49 path interaction, BPA has established an additional TRM on Northern Intertie S>N when the
50 Total Transfer Capability on this path is above 2000MW. (MOD-008-1 R1.2)

51 The amount of TRM BPA incorporates is based upon the results of the technical analyses
52 provided by Transmission System Operations. The final decision as to whether or not to
53 market any of the TRM as non-firm, up to its maximum value, is made by Transmission
54 Operations.

55 Currently, BPA applies the TRM due to variations in generation dispatch and inertial response
56 and frequency bias to its firm and non-firm ATC calculations across the Northern Intertie N>S
57 and Northern Intertie S>N ATC paths. BPA applies the TRM that is the result of allowances for
58 simultaneous path interactions to the firm ATC calculation only across the Northern Intertie
59 S>N ATC path. (MOD-008-1 R1.2)

60 Allocating TRM values across Satsop Injection

61 BPA uses the following component of uncertainty to establish TRM on its Satsop Injection ATC
62 path (MOD-008-1 R1.1):

63 ○ Forecast uncertainty in Transmission system topology (including, but not limited to,
64 forced or unplanned outages and maintenance outages).

65 ~~BPA has identified uncertainty across the Satsop Injection path due to forecast uncertainty in~~
66 ~~Transmission system topology. In order to~~To mitigate ~~thi~~se uncertainty ~~that results from this,~~
67 BPA has established a TRM when the Total Transfer Capability on this path is above 200MW.
68 ~~(MOD-008-1 R1.2)~~

69 The amount of TRM BPA incorporates is based upon the results of the technical analyses
70 provided by Transmission System Operations. The final decision as to whether or not to
71 market any of the TRM as non-firm, up to its maximum value, is made by Transmission
72 Operations.

73 Currently, BPA applies the TRM for Satsop Injection to the firm ATC calculation across this
74 path. ~~(MOD-008-1 R1.2)~~

75 **TRM for Each Time Period**

76 BPA uses the same TRM calculation described above for the same day and real-time, day-
77 ahead and pre-schedule, and beyond day-ahead and pre-schedule, up to thirteen months
78 ahead time periods. ~~(MOD-008-1 R1.3, MOD-008-1 R1.3.1, MOD-008-1 R1.3.2 and MOD-008-1~~
79 ~~R1.3.3)~~

80 BPA establishes TRM values in accordance with its TRMID at least once every 13 months.
81 ~~(MOD-008-1 R4)~~

82 **Sharing TRM**

83 The results of BPA's Transmission System Operations² TRM studies are shared electronically
84 with BPA's Transmission Planner and Transmission Service Provider no more than seven
85 calendar days after they are completed. ~~(MOD-008-R5)~~

86 **IV. TRMID Requests**

87 BPA makes its TRMID available on its [ATC Methodology](#) website ~~for all interested parties~~. If
88 requested, ~~BPA will provide a written response within 45 calendar days of receiving a written~~
89 ~~request for clarification of its TRMID from any registered entity that demonstrates a reliability~~
90 ~~need.~~

91 ~~BPA will make available the underlying documentation used to determine its TRM, in the~~
92 ~~format used by BPA, to Transmission Service Providers, Reliability Coordinators, Planning~~
93 ~~Coordinators, Transmission Planners and Transmission Operators who make a written request.~~
94 ~~BPA will supply this information no more than 30 calendar days after receiving the request~~
95 ~~(MOD-008-1 R3).~~

96 Requests ~~for this documentation~~ relating to BPA's TRM or TRMID should be sent to
97 nercatcstandards@bpa.gov.

98

V. Version History

TRMID Revision History			
Version	Date Revised	Description of Changes	Prepared by
1.0	02/13/2012	BPA TRMID FINAL	L. Trolese
2.0	2/12/2013	P. 3 lines 20-22: Updated the components used to establish TRM to Variations in Generation Dispatch and Inertial Frequency. P. 3 lines 27-34: Updated BPA's practice for Establishing TRM values across the Northern Intertie Path.	L. Wickizer
3.0	1/3/2016	P.3 lines 23-25: Updated BPA's practice for Establishing TRM values across the Northern Intertie Path S>N P.4 lines 39-48: Added establishing TRM values across the Northern Intertie Path S>N. P. 4 lines 62-69: Updated BPA's practice for System Operations analyzing and providing TRM value.	L. Proctor
4.0	9/6/2016	P4. Lines 37-45: Clarified section describing the TRM across Northern Intertie S>N due to simultaneous path interactions; added line numbers and page numbers, among other minor formatting adjustments.	M. Olczak
5.0	10/12/2018	Clarification and simplification of BPA's TRMID document. BPA's TRM methodology and calculations have not changed.	M. Olczak
6.0	08/14/2019	P3. Lines 20-23 and P4. Lines 47 - 57: TRM information for the West of Garrison E>W path has been incorporated into the document	M. Olczak
7.0	09/16/2020	P3. Lines 24-27, P4. Lines 62-72: TRM information for the Satsop Injection Path has been incorporated into the document P4. Lines 45 and 59: Clarified that Transmission Operations is responsible for making decisions about how much of the TRM is offered to the market as non-firm	M. Olczak

TRMID Revision History			
8.0	10/21/2022	Throughout document: changed "California-Oregon AC Intertie" to "AC Intertie (NWACI)" and "Northern Intertie Total" to "Northern Intertie" to properly reflect these path names; removed capitalization from "path" as this is not an officially defined term in the NERC glossary	M. Olczak
9.0	09/27/2023	p.3, lines 4-6: added that this TRMID also addresses the requirements in NAESB's WEQ-023 TRM information for the West of Garrison E>W path has been removed from the document, as technical studies indicate this TRM is no longer needed	M. Olczak