



Capacity Management and Tagging Provisions for Transactions through Hot Springs

Effective: 06/01/09

Avista, BPA, Idaho Power, NorthWestern Energy, and PacifiCorp have worked together on managing the capacity across the West of Garrison path, including the Hot Springs Substation. The result is the implemented capacity management procedures associated with the Hot Springs POR/POD, the Amps Line, and the Montana-to-Northwest Path. These are described in the Attachments and detailed in the tagging examples.

These "generic" tagging examples show flow from, to, and/or through the BPAT Balancing Authority Area. For transactions that flow to/from/through the Avista Balancing Authority Area. Postings for similar tagging examples are provided on Avista's, Northwestern Energy's, and PacifiCorp's websites.

For questions about tagging the BPAT segments call the BPA Transmission Services Real-Time desk at (360) 418-2878.

Tagging Example - West to East

Note: The OATI system screenshots included in this document are proprietary and not to be used outside the context of this document. Do not distribute without specific authorization from OATI.

| Physical Path | | | | | | |
|---------------|-----------|--------|-----------|-----------|------|----------|
| CA | TP | PSE | POR | POD | SE | Contract |
| | BPAT | "----" | "----" | BPAT.NWMT | BPAT | BPAT TSR |
| | <AMPS TP> | "----" | BPAT.NWMT | BRDY | NWMT | "---" |
| | <AMPS TP> | "----" | BPAT.NWMT | BRDY | PACE | "---" |
| | <AMPS TP> | "----" | BPAT.NWMT | BRDY | IPCO | "---" |

Tagging Example - East to West

| Physical Path | | | | | | |
|---------------|-----------|--------|-----------|-----------|--------|----------|
| CA | TP | PSE | POR | POD | SE | Contract |
| | "----" | "----" | "----" | BRDY | "----" | "---" |
| | <AMPS TP> | "----" | BRDY | BPAT.NWMT | IPCO | "---" |
| | <AMPS TP> | "----" | BRDY | BPAT.NWMT | PACE | "---" |
| | <AMPS TP> | "----" | BRDY | BPAT.NWMT | NWMT | "---" |
| | BPAT | "----" | BPAT.NWMT | "----" | BPAT | BPAT TSR |