

RePowering Wind Turbines

By Cherilyn Randall
Joint Operating Committee
February 26, 2020



Material Modification or New Request?

- Are you increasing the Nameplate?
 - New request
- Are you changing the blades?
 - How far are you from BPA's transmission lines
 - Requires a safety check – no request, no deposit
- Anything else?
 - Courtesy notice please, may need minor updates of your interconnection agreement.

Bottom Line. . .

- Call your CSE or AE when you are in the planning stage

